Waikato Building Consent Group	Final Inspection: General (Building and Plumbing)								
Applicant's Name: Property	BC No: Lot Wind								
Address: ITEMS TO BE CHECKED [Checked against the approved Building	No.: Zone:								
Key: Decision:									
REVIEW: Approved BC documents and amendments on site Prior inspection passed or instructions addressed Consent conditions checked									
Final Building									
Interior Ceiling insulation is in place / clear of light fittings Safety glass installed Wet areas completed: correct installation of shower / bath / laundry, surface areas sealed Kitchen completed Smoke alarms installed and operational Height of window sashes / restrictors Heights of barriers & handrails as per approved plans Ventilation to internal spaces Mechanical ventilation vented to exterior Firewall integrity Fire rating complete Heater checklist completed Yes No NA Exterior Pools checklist completed Yes No NA Catterior Flashing / sealants completed & in place Ground height complies (at time of inspection) Landscaping completed: Yes No NA (at time of inspection) Brick veneer weep and ventilation holes	Exterior (continued) Weathering and penetrations: roof and walls (fixings etc.). Flashing / sealants completed & in place Construction of decks / steps / retaining walls / handrails, barriers and ramps comply Sub floor ventilation Exterior finishing's Drip edge to flat surfaces Reflectivity of finishes CCC application Received Outstanding NA All producer statements Received Outstanding NA Gas certificate(s) Received Outstanding NA Heater installation statement Received Outstanding NA Waterproofing certificate Received Outstanding NA Waterproofing certificate Received Outstanding NA Records of Work Received Outstanding NA Other: Received Outstanding NA								
Comments if required: ☐ Photos attached (if relevant) ☐	□ Memo / Instruction No: □ Verbal instruction (specify):								















Final Plumbing / Drainage	BC No.:							
Exterior ☐ Pipes insulated outside building envelope using UV protection where required ☐ Gully dish heights & position to stop stormwater ingress ☐ Ensure overflow gully minimum 150 mm below lowest	Commercial ☐ Waste to commercial machine as per installation specifications (temp > 65°C) ☐ Bain-marie drains provided to approved outlet ☐ Plumbing roof penetrations flashed							
fixture All wastes are vented if greater than 3.5 m Check terminal vent through roof & check flashing Waste pipes sealed at point of entry into rear of gully dishes as per G13 or bends installed tight to gully dish Downpipes clipped & connected to stormwater drainage Downpipes from top storey roofs to lower roof spreader required (E2/8.1.6, pp.56, Fig. 20). Not allowed for masonry tile roof unless have underlay fitted If timber floor: check wastepipe falls and supports Drainage discharges into silt trap Overflows fitted to deck and Internal gutters run to exterior Interior Smoke alarms installed and operational Fire rating complete HWC correct type / valves & seismic restraints provided HWC expansion / relief drains via tundish installed and conveyed to exterior HWC tray in place Tub / Toilet cistern fixed securely Dishwasher pipe clamped and anti-siphon bend fitted	Documents Required by Building Consent As Laid plans							
Water temperature:°C	Memo / Instruction No: □ Verbal instruction (specify):							
NOTE: The project must pass final inspections and the BCA must be supplied with the required information as per the Form 5 to an adequate standard, to ensure your CCC can be issued.								
OUTCOME OF DECISIONS [Tick the correct outcome: e	.g. ☑ PASS or ☑ FAIL etc.]							
Work complies with the approved BC documents ☐ PASS ☐ FAIL. work may proceed to next inspection. FAIL. Repeat inspection required ☐ Additional fee	REPEAT: Work complies with the approved BC documents PASS FAIL. Work may proceed to next inspection. FAIL. Repeat inspection required Additional fee							
Officer Name: Signature: Date:	Officer Name: Signature: Date:							
olynatule.	orginature.							

















Page 2 of 3

ACCECCMENT	TATION RECEIVED
// / F / / / F /	//

BC No.:

Key for statement types: Cladding (CL) Electrical (EL) Engineer / Designer (PS4) Gas (GS) Glazing (GL) Insulation (IN) As-laid drainage (ALD) Pressure test (P) Smoke alarm (SM) Sprinklers (SP) Surveyors confirmation of height / siting (SV) Waterproofing (WP) Solar systems (S) Truss layout (TR) Under floor / tile heating (H) Other (O) [specify].

	Decisions Regarding Document Content (✓/Y/P = Pass × /N/F = Fail I/-/						Decision Regarding Author registration					Reason for decision	Outcome of decision Accept		
Record the Author's Name (Not the company name). If author providing more than one document, list and assess each document)	Statement type / Header (see keys above)	Site Address / Legal description	Insurance	Date	B. Code (parts)	Work identified	Name & signature	CPEng register (Engineers)	NZRAB register (Reg. Architects)	EWRB register (Energy work)	PGD register (Plumbers, Drainlayers)	WBCG register	MCMC Register	content adequate / author approved / other reason recorded below# × / N / F = content inadequate / author not approved / other recorded below#	document or Reject document

#Other reason(s) for decision(s): (Use this area for "other" statement types, or for giving reasons for decisions where a statement is not complete or an author is not registered, but you are accepting their statement)













