

# Plumbing Pressure Test Memorandum

Issued by:  
(Plumber)

Registration  
Number:

Company  
Name:

Company  
Address:

Company  
Contact  
Details: Ph:

Mb:

Fx:

To:  Hamilton City Council  Hauraki District Council  Matamata-Piako District Council  Otorohanga District Council  
 Thames-Coromandel District Council  Waikato District Council  Waipa District Council  Waitomo District Council

Building  
Consent  
Number:

Building  
Owner:

Project  
Address:

Description  
of Building  
Work:

Completion of a pressure test on the plumbing system

Scope of work  
covered by  
statement:

We certify that the system was tested to 1500kpa for a period of 30 minutes. This test was conducted in accordance with manufacturer recommendations and complies with the pressure testing provisions of the New Zealand Building Code and Approved Solution G12 AS1 and AS/NZS3500.1.2 as appropriate.

I understand that this Statement, if accepted, may be relied upon for the purpose of establishing compliance with the Building Code and Building Consent.

Signed by:  
(Plumber)

Date: